



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Municipal Building, Weekly Market Street,
Sivagangai - 630 561

Phone: 04575 - 243178

E-mail: wtlsvg@gmail.com

TEST REPORT

Doc.No: DWT1/FORM/7.8/01

Report No:	TR/2024/ 27999-1	Report Issue Date :	19.06.2025	Page No : 01 of 01
Invoice Details:	191 /Dt.14.06.2025			

Client Name & Address		:	BSR Green Park, International School, CBSE Curriculum, Thanipatti Vizhaku, Sivagangai Road, Thiruppathur, Sivagangai District - 630 211			
Contact No / Email.ID		:				
Sample Name		:	Water			
Sample Number		:	27999-1			
Sample Description		:	R.O.Water			
Sample Submitted by		:	M.Ganesan			
Location & Date		:	Inside the School Campus & 14.06.2025			
Quantity of sample Received		:	2 Litre			
Sample Container		:	Jerry Cane			
Sample Condition on Receipt		:	Good			
Sample Received On		:	14.06.2025			
Test Commenced on		:	14.06.2025			
Test Completed on		:	19.06.2025			
Environmental Condition		:	25.0°C – 28.0°C			
S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25 ⁰ C	-	IS 3025 Part 11-1983	6.72	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	mg/L	IS 3025 Part 21-2009	32	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part 23-1986	24	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	30	250	1000
5	Sulphate as SO4	mg/L	IS 3025-Part 24-1986	0	200	400
6	Nitrate as NO ₃	mg/L	APHA 23rd Edition 2017- 4500 -NO3 B	0	45	45
7	Fluoride as F	mg/L	APHA 23rd Edition 2017 – 4500- F-D	0.16	1.0	1.5

Remark: The tested sample conformed to IS: 10500:2012 (RA: 2019) Drinking water specification with respect to above tested parameters. The Decision rule is not applicable.

.....End of the report.....


Authorised Signatory
M.Dinesh Kumar
Assistant Executive Engineer,

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Municipal Building, Weekly Market Street

Sivagangai – 630 561

Phone: 04575 - 243178

E-mail: wtlsvg@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/ 27999 - 2	Report Issue Date :	19.06.2025	Page No:01 of 02
Invoice Details:	191 /Dt.14.06.2025			

Client Name & Address
Contact No / Email.ID

: BSR Green Park, International School,
CBSE Curriculum, Thanipatti Vizhaku,
Sivagangai Road, Thiruppathur,
Sivagangai District - 630 211

Sample Name	: Water
Sample Number	: 27999-2
Sample Description	: R.O.Water
Sample Submitted by	: M.Ganesan
Location & Date	: Inside the School Campus & 14.06.2025
Quantity of sample Received	: 2 Litre
Sample Container	: Jerry Cane
Sample Condition on Receipt	: Good
Sample Received On	: 14.06.2025
Test Commenced on	: 14.06.2025
Test Completed on	: 19.06.2025
Environmental Condition	: 25.0°C – 28.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	–	Clear	Clear	Clear
2	Odour	IS 3025 Part 5 : 1983	–	Agreeable	Agreeable	Agreeable
3	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5
4	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	84	500	2000
5	Conductivity	APHA 23rd Edition 2017 – 2510 B	µS/cm	120	-	-
6	P - Alkalinity	IS 3025-Part 23-1983	mg/L	NIL	-	-
7	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	0	75	200
8	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	0	30	100
9	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0	0.3	1
10	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	0	0.1	0.3
11	Ammonia as NH ₃	APHA 17th Edition-1989– 4500 NH ₃ C	mg/L	0	0.5	0.5

Authorised Signatory

M.Dinesh Kumar

Assistant Executive Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Municipal Building, Weekly Market Street

Sivagangai - 630 561

Phone: 04575 - 243178

E-mail: wtlsvvg@gmail.com

TEST REPORT

Doc.No: DWTI/FORM/7.2/91

Report No:	TR/2024/ 27999 - 2	Report Issue Date :	19.06.2025	Page No:02 of 02
Invoice Details:	191 /DL.14.06.2025			

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
12	Nitrite as NO ₂	APHA 23rd Edition 2017-4500-NO2 B	mg/L	0	-	-
13	Total Phosphate as PO ₄	APHA 23rd Edition 2017 - 4500 P- D	mg/L	0	-	-
14	Tidys 4 hr. test	APHA 23rd Edition 2017 - 4500 O - B	mg/L	0	-	-
15	Residual Chlorine	IS/APHA	mg/L	0	0.2	1.0
BACTERIOLOGICAL EXAMINATION						
16	Fecal Coliform	IS/APHA	CFU/100ML	0	0	0

Report: :The tested sample conformed to IS:10500:2012(RA: 2019)drinking water specification with respect to above tested parameters.

.....End of the report.....


Authorised Signatory
M.Dinesh Kumar
Assistant Executive Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



SANITARY CERTIFICATE

THE TAMILNADU EDUCATIONAL RULES CHAPTER-III
(Rule 24 & Appendix-3)


I hereby declare that I have caused to be inspect the building and premises of **BSR GREEN PARK INTERNATIONAL SCHOOL, T.VAIRAVANPATTI, THIRUKOSTIYUR, THIRUPATHUR, Sivagangai District** on 24.04.2025 and certify that the accommodation provided for each and the several class rooms are sufficient for the maximum number of pupils stayed therein and is properly ventilated and lighted. That the building is maintained with substantial repairs and is neat and clean that the latrine arrangements are adequate and satisfactory, that the supply of drinking water is wholesome and that in all other necessary aspects the sanitation is satisfactory.

This certificate is valid one year from the date of issued

Certificate is issued with the following conditions:

1. Establishing hand wash facilities at the entrance.
2. Toilets and Urinals must be kept hygienically clean and adequate water supply should be provided.
3. Environment and campus should be kept clean and neat and should be free from Dengue Aedes Larva.
4. Provide safe and protected drinking water.
5. First Aid box should be maintained with drug properly.
6. Tobacco prohibition board should be displayed as per COTPA 2003.
7. Building License Form-D must be submitted within a period of 03 Months.


தொழில்நுட்ப நேர்முக உதவியாளர்
மாவட்ட சுகாதார அலுவலர் அலுவலகம்
சிவகங்கை.


Block Health Supervisor,
Govt. Primary Health Centre,
Nerkuppai, Thiruppathur Block

Ref. L. Dis. No. 3097/A6/2025 O/o. District Health Officer, Sivagangai Dt. 05/05/2025
Counter signed based on the Block Health Supervisor's inspection reports

Counter signed


District Health Officer,
Sivagangai