



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126SVG34591

Issued Date : 13-05-2026

Organization Type : Educational Institutions

Expiry Date : 12-05-2027


Name of the Organization : BSR GREEN PARK INTERNATIONAL SCHOOL

Address : S.NO-64/1B2B,64/10,61/1B1,1B2 & 1C,T.BAIRAVANPATTI VILLAGE,THIRUKOSHTIYUR PANCHAYAT,THIRUPPATHUR TALUK,SIVAGANGAI

I, ALAMIN ISLAMIC PARK INTERNATIONAL SCHOOL owner/manager of the BSR GREEN PARK INTERNATIONAL SCHOOL functioning as Educational Institutions located at T. Vairavanpatti in Sivagangai district hereby declare that

- This Self-Declared Sanitation certificate is valid from 13-05-2026 to 12-05-2027 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 69 people/pupils and has 15 urinals and 20 toilets which is proportionate to the number of users as per government norms.
- 2 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.



Signature of the Owner/Manager



(அ) TN00126SVG34591 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பार्சுகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126SVG34591 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Municipal Building, Weekly Market Street,
Sivagangai - 630 561

Phone: 04575 - 243178

E-mail:wtlsvg@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/ 27999-1	Report Issue Date :	19.06.2025	Page No : 01 of 01
Invoice Details:	191 /Dt.14.06.2025			

Client Name & Address : BSR Green Park, International School,
Contact No / Email.ID : CBSE Curriculum, Thanipatti Vizhaku,
Sivagangai Road, Thiruppathur,
Sivagangai District - 630 211

Sample Name : Water
Sample Number : 27999-1
Sample Description : R.O.Water
Sample Submitted by : M.Ganesan
Location & Date : Inside the School Campus & 14.06.2025
Quantity of sample Received : 2 Litre
Sample Container : Jerry Cane
Sample Condition on Receipt : Good
Sample Received On : 14.06.2025
Test Commenced on : 14.06.2025
Test Completed on : 19.06.2025
Environmental Condition : 25.0°C – 28.0°C

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25 ⁰ C	-	IS 3025 Part 11-1983	6.72	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	mg/L	IS 3025 Part 21-2009	32	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part 23-1986	24	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	30	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025-Part 24-1986	0	200	400
6	Nitrate as NO ₃	mg/L	APHA 23rd Edition 2017- 4500 -NO ₃ B	0	45	45
7	Fluoride as F	mg/L	APHA 23rd Edition 2017 - 4500- F-D	0.16	1.0	1.5

Remark: The tested sample conformed to IS: 10500:2012 (RA: 2019) Drinking water specification with respect to above tested parameters. The Decision rule is not applicable.

.....End of the report.....


Authorised Signatory
M.Dinesh Kumar
Assistant Executive Engineer,

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Municipal Building, Weekly Market Street

Sivagangai – 630 561

Phone: 04575 - 243178

E-mail: wtlsvg@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/ 27999 - 2	Report Issue Date :	19.06.2025	Page No:01 of 02
Invoice Details:	191 /Dt.14.06.2025			

Client Name & Address Contact No / Email.ID	: BSR Green Park, International School, CBSE Curriculum, Thanipatti Vizhaku, Sivagangai Road, Thiruppathur, Sivagangai District - 630 211
Sample Name	: Water
Sample Number	: 27999-2
Sample Description	: R.O.Water
Sample Submitted by	: M.Ganesan
Location & Date	: Inside the School Campus & 14.06.2025
Quantity of sample Received	: 2 Litre
Sample Container	: Jerry Cane
Sample Condition on Receipt	: Good
Sample Received On	: 14.06.2025
Test Commenced on	: 14.06.2025
Test Completed on	: 19.06.2025
Environmental Condition	: 25.0°C – 28.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Visual observation	--	Clear	Clear	Clear
2	Odour	IS 3025 Part 5 : 1983	--	Agreeable	Agreeable	Agreeable
3	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5
4	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	84	500	2000
5	Conductivity	APHA 23rd Edition 2017 – 2510 B	µS/cm	120	-	-
6	P - Alkalinity	IS 3025–Part 23-1983	mg/L	NIL	-	-
7	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	0	75	200
8	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	0	30	100
9	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0	0.3	1
10	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	0	0.1	0.3
11	Ammonia as NH ₃	APHA 17th Edition-1989– 4500 NH ₃ C	mg/L	0	0.5	0.5

M.D. Dinesh Kumar
Authorised Signatory
M.Dinesh Kumar
Assistant Executive Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Municipal Building, Weekly Market Street
Sivagangai – 630 561

Phone: 04575 - 243178

E-mail: wtlsvg@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/ 27999 - 2	Report Issue Date :	19.06.2025	Page No:02 of 02
Invoice Details:	191 /Dt.14.06.2025			

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
12	Nitrite as NO ₂	APHA 23rd Edition 2017– 4500-NO2 B	mg/L	0	-	-
13	Total Phosphate as PO ₄	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0	-	-
14	Tidys 4 hr. test	APHA 23rd Edition 2017 – 4500 O - B	mg/L	0	-	-
15	Residual Chlorine	IS/APHA	mg/L	0	0.2	1.0
BACTERIOLOGICAL EXAMINATION						
16	Fecal Coliform	IS/APHA	CFU/ 100ML	0	0	0

Report: :The tested sample conformed to IS:10500:2012(RA: 2019)drinking water specification with respect to above tested parameters.

.....End of the report.....


Authorised Signatory
M.Dinesh Kumar
Assistant Executive Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Municipal Building, Weekly Market Street,
Sivagangai - 630 561

Phone: 04575 - 243178

E-mail: wtlsvg@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/ 27998-1	Report Issue Date :	19.06.2025	Page No : 01 of 01
Invoice Details:	191 /Dt.14.06.2025 Amt.Rs.2832/-			

Client Name & Address : BSR Green Park, International School,
Contact No / Email.ID : CBSE Curriculum, Thanipatti Vizhaku,
Sivagangai Road, Thiruppathur,
Sivagangai District - 630 211

Sample Name : Water
Sample Number : 27998-1
Sample Description : Bore Well Water
Sample Submitted by : M.Ganesan
Location & Date : Inside the School Campus & 14.06.2025
Quantity of sample Received : 2 Litre
Sample Container : Jerry Cane
Sample Condition on Receipt : Good
Sample Received On : 14.06.2025
Test Commenced on : 14.06.2025
Test Completed on : 19.06.2025
Environmental Condition : 25.0°C – 28.0°C

S.No	Parameters	Unit	Test Method	Result	Specification as per IS 10500:2012(RA:2019)	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25 ^o C	-	IS 3025 Part 11-1983	7.84	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	mg/L	IS 3025 Part 21-2009	312	200	600
3	Total Alkalinity as CaCO ₃	mg/L	IS 3025-Part 23-1986	620	200	600
4	Chloride as Cl	mg/L	IS 3025-Part 32-1988	445	250	1000
5	Sulphate as SO ₄	mg/L	IS 3025-Part 24-1986	34	200	400
6	Nitrate as NO ₃	mg/L	APHA 23rd Edition 2017- 4500 -NO3 B	5	45	45
7	Fluoride as F	mg/L	APHA 23rd Edition 2017 - 4500- F-D	0.77	1.0	1.5

.....End of the report.....


Authorised Signatory

M.Dinesh Kumar
Assistant Executive Engineer,

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Municipal Building, Weekly Market Street
Sivagangai – 630 561

Phone: 04575 - 243178

E-mail: wtlsvg@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/ 27998-2	Report Issue Date :	19.06.2025	Page No:01 of 02
Invoice Details:	191 /Dt. 14.06.2025			

Client Name & Address : BSR Green Park, International School,
Contact No / Email.ID : CBSE Curriculum, Thanipatti Vizhaku,
Sivagangai Road, Thiruppathur,
Sivagangai District - 630 211

Sample Name	:	Water
Sample Number	:	27998-2
Sample Description	:	Bore Well Water
Sample Submitted by	:	M.Ganesan
Location & Date	:	Inside the School Campus & 14.06.2025
Quantity of sample Received	:	2 Litre
Sample Container	:	Jerry Cane
Sample Condition on Receipt	:	Good
Sample Received On	:	14.06.2025
Test Commenced on	:	14.06.2025
Test Completed on	:	19.06.2025
Environmental Condition	:	25.0°C – 28.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
8	Appearance	Visual observation	--	Clear	Clear	Clear
9	Odour	IS 3025 Part 5 : 1983	--	Agreeable	Agreeable	Agreeable
10	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5
11	Total Dissolved Solids	APHA 23rd Edition 2017 – 2540 C	mg/L	1680	500	2000
12	Conductivity	APHA 23rd Edition 2017 – 2510 B	μS/cm	2400	-	-
13	P - Alkalinity	IS 3025-Part 23-1983	mg/L	NIL	-	-
14	Calcium as Ca	APHA 23rd Edition 2017 – 3500 Ca B	mg/L	62	75	200
15	Magnesium as Mg	APHA 23rd Edition 2017– 3500 Mg B	mg/L	37	30	100
16	Iron as Fe	APHA 23rd Edition 2017– 3500 Fe B	mg/L	0	0.3	1
17	Manganese as Mn	APHA 23rd Edition 2017 – 3500 Mn B	mg/L	0	0.1	0.3
18	Ammonia as NH ₃	APHA 17th Edition-1989– 4500 NH ₃ C	mg/L	0.6	0.5	0.5


Authorised Signatory
M.Dinesh Kumar
Assistant Executive Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Municipal Building, Weekly Market Street

Sivagangai – 630 561

Phone: 04575 - 243178

E-mail: wtlsvg@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Report No:	TR/2024/ 27998-2	Report Issue Date :	19.06.2025	Page No:02 of 02
Invoice Details:	191 /Dt. 14.06.2025			

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
19	Nitrite as NO ₂	APHA 23rd Edition 2017– 4500-NO2 B	mg/L	0.2	-	-
20	Total Phosphate as PO ₄	APHA 23rd Edition 2017 – 4500 P- D	mg/L	0.8	-	-
21	Tidys 4 hr. test	APHA 23rd Edition 2017 – 4500 O - B	mg/L	0.32	-	-
22	Residual Chlorine	IS/APIHA	mg/L	0	0.2	1.0
BACTERIOLOGICAL EXAMINATION						
23	Fecal Coliform	IS/APIHA	CFU/ 100ML	40	0	0

Report: :The tested sample is not conformed to IS:10500:2012(RA: 2019)drinking water specification with respect to above tested parameters.

.....End of the report.....


Authorised Signatory
M.Dinesh Kumar
Assistant Executive Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.